

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0085:199 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: ADT, 5400 Rosecrans Ave., Hawthorne, CA 90250-6609
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Model H2351ADT photoelectric type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as photoelectric type smoke detector for use with listee's separately listed compatible base and fire alarm control units. Suitable for open areas and inside duct installation with air velocities between 0-4000 fpm.

XLf: 7272-0028:206

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager